



- NOTES: 1. FINISH WITH APPROVED FIRE HYDRANT MARINE YELLOW 1000 PAINT, MANUFACTURED BY PROLINE.
2. ALL BURIED NUTS AND BOLTS TO BE STAINLESS STEEL.
3. PLACE DETECTOR TAPE MARKED "WATER" 1 FOOT ABOVE PIPE ALONG ENTIRE RUN.
4. ALL DUCTILE IRON PIPE AND FITTINGS SHALL BE ENCASED WITH 2 LAYERS OF 8 MIL POLYETHYLENE.

- * WHEN BLOW-OFF IS LOCATED BEHIND THE SIDEWALK.
** WHEN BLOW-OFF IS LOCATED IN A PLANTED PARKWAY.

Revision	By	Approved	Date	CITY OF OCEANSIDE	
09/11/00	kal			STANDARD BLOW-OFF	<i>John D. Kelly</i> 9.20.07 CITY ENGINEER Date STANDARD DRAWING NO. W-2
10/16/02	DW				
08/04/04	AC				
06/04/07	AC	<i>CS</i>	7/07		