



NO.	QUANT.	FITTINGS
①	2	STD. 6" VALVE CAN AND COVER PER SUPPLEMENTAL W-23.
②	2	STD. R/W GATE VALVE FLG X PO
③	1	FLANGED D.I.P. CEMENT LINED SPOOL
④	1	NON SLAM CHECK VALVE CLAYTON 81G-02 GLOBE**
⑤	1	TWO CONCENTRIC MANHOLE COVERS WITH 48" AND 22" OPENINGS

**FACTORY FUSION - BONDED EPOXY COATING INSIDE AND OUT W/STAINLESS STEEL TRIM.

VALVE SIZE	W	H	D
6"	21"	13 5/8"	6"
8"	26 3/8"	15 1/4"	7 5/8"
10"	31 1/8"	17"	9 1/4"
12"	35 1/2"	21"	10 3/4"

1. PAINT VALVES & PIPE PER W-17.
2. COAT INTERIOR WITH SANCON 100 OR ZEBRON.
3. WATERPROOF EXTERIOR AS REQUIRED.
4. VALVE SUPPORTS (PER W-18) TO BE INSTALLED AT BOTH ENDS OF THE CHECK VALVE.
5. CHECK VALVE TO BE CENTERED HORIZONTALLY UNDER CONCENTRIC MANHOLE COVERS.

Revision	By	Approved	Date
11/09/00	kal		
06/08/01	DW		
10/16/02	DW		
07/08/04	AC		

CITY OF OCEANSIDE

CHECK VALVE

CITY ENGINEER *[Signature]* Date

STANDARD DRAWING NO. W-15