

- 1. SERVICE SADDLE, CORPORATION STOP AND ANGLE METER STOP PER SECTION 4.5.
- 2. COPPER TUBING SHALL BE TYPE "K" SEAMLESS SOFT. (NO JOINTS PERMITTED).
- 3. SERVICE SADDLE, CORPORATION STOP AND ANGLE METER STOP PER SECTION 4.5.
- 4. METER BOX TO BE INSTALLED BY CITY FORCES AT CONTRACTORS EXPENSE.
- 5. SERVICES TO BE ENCASED IN 6" NEUTRAL SAND.
- 6. BURIED COPPER TO BE ENCASED IN 6 MIL POLY SLEEVE SECTION 4.5.
- 7. WATER PORT HOLE CENTERS TO BE INSTALLED 10" BELOW TOP OF METER BOX.
- 8. IDENTIFICATION TAGS CHRISTY'S MODEL ID-MAX-P2-RCIP2
- 9. IDENTIFICATION TAPE CHRISTY'S MODEL TA-DT-02-PRW
- 10. IDENTIFICATION NAME PLATE CHRISTY'S MODEL 3800
- 11. PAINT ALL VALVES AND METERS INSIDE METER BOX OSHA 300 PURPLE
- 12. SEE OCEANSIDE'S WATER, SEWER, AND RECLAIMED WATER DESIGN & CONSTRUCTION MANUAL FOR APPROVED SADDLE MATERIAL.

Revis 11/07	_	By kal	Approved	Date	CITY OF OCEANSIDE	Sex l Spot 12 11
08/30	/04	AC				CITY ENGINEER Date
09/27	/10	DW			3/4" AND 1" IRRIGATION SERVICE	STANDARD
						DRAWING NO. RW-4
						DRAWING NO. 1111 4