


1. SERVICE SADDLE, CORPORATION STOP AND ANGLE METER STOP PER SECTION 4.5.
2. COPPER TUBING SHALL BE TYPE "K" SEAMLESS SOFT. (NO JOINTS PERMITTED).
3. SERVICE SADDLE, CORPORATION STOP AND ANGLE METER STOP PER SECTION 4.5.
4. METER BOX TO BE INSTALLED BY CITY FORCES AT CONTRACTORS EXPENSE.
5. SERVICES TO BE ENCASED IN 6" NEUTRAL SAND.
6. BURIED COPPER TO BE ENCASED IN 6 MIL POLY SLEEVE SECTION 4.5.
7. WATER PORT HOLE CENTERS TO BE INSTALLED 10" BELOW TOP OF METER BOX.
8. IDENTIFICATION TAGS CHRISTY'S MODEL ID-MAX-P2-RCIP2
9. IDENTIFICATION TAPE CHRISTY'S MODEL TA-DT-02-PRW
10. IDENTIFICATION NAME PLATE CHRISTY'S MODEL 3800
11. PAINT ALL VALVES AND METERS INSIDE METER BOX OSHA 300 - PURPLE
12. SEE OCEANSIDE'S WATER, SEWER, AND RECLAIMED WATER DESIGN & CONSTRUCTION MANUAL FOR APPROVED SADDLE MATERIAL.

Revision	By	Approved	Date	CITY OF OCEANSIDE	 CITY ENGINEER Date
11/07/00	kal				
08/30/04	AC			3/4" AND 1" IRRIGATION SERVICE	STANDARD DRAWING NO. RW-4
09/27/10	DW				