



- ① MASTER METER SERIES "W" TURBO METER WITH BUILT IN STRAINER & TEST OUTLET APPROXIMATELY 23" LONG.
- ② VAULT FRAME AND COVER PER STD. DWG RW-13, AND RW-14.
- ③ VICTAULIC COUPLING.
- ④ GATE VALVE, FLANGE X FLANGE WITH 2" OPERATING NUT.
- ⑤ SUPPORT METER WITH VALVE SUPPORTS PER RW-12.

NOTES: VAULT DEPTH NOT TO EXCEED 5'-0" FROM TOP OF VAULT TO FLOOR.
SERVICES 6" AND LARGER REQUIRE SPECIAL DESIGN.

Revision	By	Approved	Date	CITY OF OCEANSIDE 3" & 4" TURBO-METER FOR IRRIGATION SERVICE	CITY ENGINEER <i>[Signature]</i> 12-1-10 Date
04/26/01	kal				
06/07/01	DN				
10/16/02	DN				
08/30/04	AC				
09/23/10	DN				STANDARD DRAWING NO. RW-6