



NO.	QUANT.	FITTINGS
①	2	STD. 6" VALVE CAN AND COVER PER SUPPLEMENTAL RW-15.
②	2	STD. GATE VALVE FLG X PO
③	1	FLANGED D.I.P. CEMENT LINED SPOOL
④	1	NON SLAM CHECK VALVE CLAYTON 81G-02 GLOBE**
⑤	1	TWO CONCENTRIC MANHOLE COVERS WITH 48" AND 22" OPENINGS MARKED "OCEANSIDE WATER DEPARTMENT RECLAIMED WATER"
⑥	1	CHRISTY'S WARNING TAG MODEL ID-MAX-P2-RCIP2

**FACTORY FUSION - BONDED EPOXY COATING INSIDE AND OUT W/STAINLESS STEEL TRIM.

VALVE SIZE	W	H	D
6"	21"	13 5/8"	6"
8"	26 3/8"	15 1/4"	7 5/8"
10"	31 1/8"	17"	9 1/4"
12"	35 1/2"	21"	10 3/4"

1. ALL VALVES AND PIPING WITHIN THE VAULT SHALL BE PAINTED OSHA 300 PURPLE
2. COAT INTERIOR WITH EITHER SANCON 100 OR ZEBRON.
3. WATERPROOF EXTERIOR AS REQUIRED BY THE ENGINEER.
4. VALVE SUPPORTS PER RW-12 TO BE INSTALLED AT BOTH ENDS OF THE CHECK VALVE.
5. CHECK VALVE TO BE CENTERED HORIZONTALLY UNDER CONCENTRIC MANHOLE COVERS.

Revision	By	Approved	Date
11/09/00	kal		
08/30/04	AC		

CITY OF OCEANSIDE

CHECK VALVE

CITY ENGINEER *h. taylor* Date *8/8/15*

STANDARD DRAWING NO. **RW-9**