



1. PRESSURE RELIEF VALVE CLAYTON 50G-01 WITH FACTORY FUSION BONDED EPOXY COATING INSIDE AND OUT W/STAINLESS STEEL TRIM.
  2. DUCTILE IRON FLANGED SPOOL, LENGTH AS REQUIRED.
  3. FLNG. GATE VALVE /RW (RESILIENT WEDGE VALVE) W/FACTORY FUSION BONDED EPOXY COATING INSIDE. WEDGE TO BE URETHANE RUBBER ENCAPSULATED DUCTILE IRON.
  4. DIP CL 150 OR PVC C900 CL 150, LENGTH 10'-15' TO DAYLIGHT OR DISCHARGE TO BE DESIGNED FOR A SPECIFIC SITE CONDITION. DIP TO BE WRAPPED PER SECTION 4.5.
  5. PRE-CAST VAULT PER STANDARD DWG RW-13.
  6. COVER PER STANDARD DWG RW-14
  7. VALVE SUPPORT PER STANDARD DWG NO. RW-12.
  8. VALVE BOX PER STANDARD DWG RW-15.
  9. FLAP GATE VALVE. IF DISCHARGE PIPE IS RELEASED TO STORM DRAIN IT MUST BE AIR-GAPPED
  10. APPROVED SEALANT AROUND PIPE OPENINGS.
  11. IF DISCHARGE PIPE IS RELEASED TO STORM DRAIN IT MUST BE AIR-GAPPED AND DIFFUSED.
- NOTE: ALL VALVES AND PIPING WITHIN THE VAULT SHALL BE PAINTED OSHA 300 - PURPLE.

Revision	By	Approved	Date
11/06/00	kal		
06/11/01	DW		
10/18/02	DW		

CITY OF OCEANSIDE

RELIEF VALVE

CITY ENGINEER *M. Dwyer* 8/8/05 Date

STANDARD  
DRAWING NO. RW-10