



BASE COURSE AND FINISH COURSE AC PER DWG. M-3C

PERMANENT RESURFACING SHALL MATCH THE EXISTING GRADE AND CROSSFALL OF THE STREET.

FOR GENERAL NOTES SEE M-3C

FOR TRENCHES WHEN NATIVE SOIL AND CLASS II IS USED AS BACKFILL  
 A REPORT PREPARED BY A REGISTERED SOILS ENGINEER SHALL BE SUBMITTED TO THE CITY. THE SOILS ENGINEER SHALL CERTIFY THAT THE BACKFILL IS WITHIN THE OPTIMUM MOISTURE RANGE AND HAS BEEN PROPERLY COMPACTED. THE BACKFILL SHALL BE TESTED AT EACH VERTICAL FOOT, AND EACH 50 LINEAR FEET OF TRENCH WITH A MINIMUM OF 1 TEST PER TRENCH.

Revision	By	Approved	Date

**CITY OF OCEANSIDE**  
**TRENCH**  
**BACKFILLING & RESURFACING**

*Ronald A. Bahr*  
 CITY ENGINEER *12/2/92* Date  
 STANDARD DRAWING NO. M-3A