



1. SPACES FOR THE HANDICAPPED SHALL BE 14' X 20'. THERE SHALL BE 1 HANDICAPPED SPACE FOR THE FIRST 40 SPACES, AND 1 ADDITIONAL SPACE FOR EVERY 40 SPACES, UP TO 160 SPACES. (OR PER TITLE 24)
2. UNIVERSAL SPACES SHALL BE 8.5' X 18'.
3. COMPACT SPACES SHALL BE 7.5' X 15'.
4. PARALLEL SPACES SHALL BE 8' X 22'.

X = STALL NOT ACCESSIBLE IN CERTAIN LAYOUTS

8.5' X 18' SPACES

DIMENSION

ON DIAGRAM

ANGLE

		45°	60°	75°	90°
STALL WIDTH, PARALLEL TO AISLE	A	12.2'	9.9'	8.8'	8.5'
STALL LENGTH OF LINE	B	22.5'	20.5'	19.5'	18.0'
STALL DEPTH TO WALL	C	16.2'	17.9'	19.0'	18.0'
AISLE WIDTH TO STALL LINES	D (1 WAY)	12.0'	16.0'	23.0'	24.0'
	D (2 WAY)	24.0'	24.0'	24.0'	24.0'
STALL DEPTH (TO INTERLOCK)	E	15.3'	17.5'	18.8'	18.0'
MODULE (WALL TO INTERLOCK)	F (1 WAY)	43.3'	51.4'	60.8'	60.0'
	F (2 WAY)	55.3'	59.4'	61.8'	60.0'
MODULE (INTERLOCKING)	G (1 WAY)	42.6'	51.0'	60.6'	60.0'
	G (2 WAY)	54.6'	59.0'	61.6'	60.0'
MODULE (INTERLOCK TO CURB FACE)	H (1 WAY)	41.3'	49.1'	58.3'	57.5'
	H (2 WAY)	53.3'	57.1'	59.3'	57.5'
BUMPER OVERHANG	I	2.0'	2.3'	2.5'	2.5'
OFFSET	J	6.3'	2.7'	0.5'	0.0'
SETBACK	K	12.5'	9.0'	4.5'	0.0'
CROSS AISLE	L (1 WAY)	14.0'	14.0'	14.0'	14.0'
	L (2 WAY)	24.0'	24.0'	24.0'	24.0'

Revision	By	Approved	Date

CITY OF OCEANSIDE

PARKING LOT LAYOUT GUIDE

Ronald A. Beech
 CITY ENGINEER *12/2/99* Date
 STANDARD DRAWING NO. **T-4**