


NOTES:

1. FINISH WITH APPROVED FIRE HYDRANT MARINE YELLOW 1000 PAINT, MANUFACTURED BY PROLINE.
2. ALL BURIED NUTS AND BOLTS TO BE TYPE 316 STAINLESS STEEL.
3. PLACE DETECTOR TAPE MARKED "WATER" 1 FOOT ABOVE PIPE ALONG ENTIRE RUN.
4. ALL DUCTILE IRON PIPE, FITTINGS, AND GALVANIZED RISER SHALL BE ENCASED WITH 2 LAYERS OF 8 MIL POLYETHYLENE.
5. ENCASE ALL FERROUS METALS IN 6" OF SE 30 SAND AFTER WRAPPING.
6. PROVIDE TRACER WIRE PER OSD W-1 FOR PVC PIPE WHERE SERVICE IS NOT PERPENDICULAR TO MAIN.



LEGEND ON PLANS

Revision	By	Approved	Date
10/16/02	DW		
08/04/04	AC		
06/04/07	AC		
05/01/17	MU		
07/01/17	SM		08/01/17

CITY OF OCEANSIDE

STANDARD BLOW-OFF

Steven E. Strapanac 9/17/17
 CITY ENGINEER Date
 STANDARD DRAWING NO. **W-2**