


BILL OF MATERIALS:

1. MASTER METER SRH COMPOUND METER WITH BUILT IN TEST OUTLET (APPROXIMATELY 20" LONG).
2. VAULT FRAME AND COVER PER STANDARD DWG W-19 AND W-20
3. VICTAULIC COUPLING.
4. RESILIENT WEDGE GATE VALVE, FLANGE X FLANGE WITH 2" OPERATING NUT (CLOSED VALVE).
5. MAINLINE BY-PASS (MAIN LINE SIZE).
6. SUPPORT METER WITH VALVE SUPPORTS PER STANDARD DWG W-18.
7. BILCO 2 PIECE OR USF 2 PIECE ALUMINUM DIAMOND PLATE HATCH. THE HATCH MUST COVER THE LIMITS OF EITHER SIDE OF THE RWGV ON THE MAIN LINE. RATING OF THE HATCH WILL BE MADE ON A CASE-BY-CASE BASIS, APPROVED BY THE WATER UTILITIES DEPARTMENT.
8. PIPELINE PRODUCTS GVL-200 LOCKING GATE VALVE CAP.

NOTES:

1. VAULT DEPTH NOT TO EXCEED 5'-0" FROM TOP OF VAULT TO FLOOR.
2. SERVICES 6" AND LARGER REQUIRE SPECIAL DESIGN.

Revision	By	Approved	Date	CITY OF OCEANSIDE 3" & 4" WATER METER FOR COMMERCIAL/INDUSTRIAL/ MULTI-FAMILY SERVICE	 9/17/17
10/16/02	DW				CITY ENGINEER Date
06/04/07	AC			STANDARD	
09/22/10	DW			DRAWING NO. W-10	
12/01/11	DW				
01/04/116	MU				
07/01/17	SM		08/01/17		