



SYSTEM TO BE INSTALLED AS PER N.F.P.A. 24. FIRE DEPT. WILL WITNESS 200 LB HYDROSTATIC PRESSURE TEST FROM BASE OF RISER TO SWING CHECK VALVE PRIOR TO CITY MAIN CONNECTION.

* REQUIRED WITH ON-SITE HYDRANT(S) ONLY

Revision	By	Approved	Date
06/11/01	DW		
09/18/02	DW		
08/29/04	AC		
09/22/10	DW		
01/04/16	MU		
07/01/17	SM		08/01/17

CITY OF OCEANSIDE

**STANDARD POST INDICATOR VALVE
INSTALLATION WITH
FIRE DEPARTMENT CONNECTION**

Steven E. Strapac 9/17/17
CITY ENGINEER Date

STANDARD DRAWING NO. **W-21**