



NOTES:

1. ALL NUTS & BOLTS TO BE TYPE 316 STAINLESS STEEL.
2. APPLY ANTI-SEIZE TO ALL S.S. BOLT THREADS.
3. ALL VALVES AND FITTINGS TO BE WRAPPED WITH 2 LAYERS OF 8 MIL POLYETHYLENE.
4. ALL FLANGE TO BE BE PRIMED AND WRAPPED WITH WAX-TAPE.
5. ALL CONCRETE TO BE 560-C-3250 (6- SACK CONCRETE MIX).

Revision	By	Approved	Date
11/08/00	kal		
09/18/02	DW		
08/29/04	AC		
01/04/16	MU		
07/01/17	SM		08/01/17

CITY OF OCEANSIDE

LINE VALVE
INSTALLATION

Steven E. Strapan 9/17/17
CITY ENGINEER Date
STANDARD DRAWING NO. **W-22**