



- ① MASTER METER SERIES "W" TURBO METER WITH BUILT IN STRAINER & TEST OUTLET APPROXIMATELY 23" LONG.
- ② VAULT FRAME AND COVER PER STD. DWG RW-13, AND RW-14.
- ③ VICTAULIC COUPLING.
- ④ GATE VALVE, FLANGE X FLANGE WITH 2" OPERATING NUT.
- ⑤ SUPPORT METER WITH VALVE SUPPORTS PER RW-12.
- ⑥ IDENTIFICATION TAGS. CHRISTY'S MODEL ID-MAX-P2-RC007

NOTE: ALL PIPING AND APPURTENANCES SHALL BE PAINTED SAFETY PURPLE.

NOTE: VAULT DEPTH NOT TO EXCEED 5'-0" FROM TOP OF VAULT TO FLOOR.
SERVICES 6" AND LARGER REQUIRE SPECIAL DESIGN.

Revision	By	Approved	Date
06/07/01	DW		
10/16/02	DW		
08/30/04	AC		
09/23/10	DW		
09/29/15	IN		
07/01/17	SM		08/01/17

CITY OF OCEANSIDE

**3" & 4" METER
FOR IRRIGATION SERVICE**

Steven E. Strapac 9/17/17
CITY ENGINEER Date
STANDARD DRAWING NO. **RW-6**