



- ARMORCAST SAMPLE CANS
MODEL NO. P6002010-SND
- * 36" OVERALL HEIGHT.
 - * LOCK-ALIGNMENT LATCH.
 - * INSIDE MOUNT & S. S. U-BOLT FOR VALVE.
 - * 1/2" HOLES IN THE THREE LEG MOUNT.
 - * 180 DEGREE LID OPENING FOR EASY ACCESS.

REINFORCED CONCRETE FOOTING
24" X 24" X 12" DEEP WITH #4 BARS
AT 7" ON CENTER EACH WAY
CENTERED IN FOOTING
POUR AGAINST 4" PVC

NOTES:

1. WATER SAMPLING LINE TEE TO BE INSTALLED PRIOR TO METER.
2. ALL COPPER JOINTS TO BE SILVER SOLDERED.
3. ALL COPPER TO BE ENCASED IN 6 MIL POLYWRAP AND 6" OF SE 30 SAND PER SECTION 2.12.
4. ALL CONCRETE TO BE 560-C-3250 PER GREEN BOOK .

Revision	By	Approved	Date
08/29/04	AC		
06/04/07	AC		
09/22/10	DW		
12/01/11	DW		
01/04/16	MU		
07/01/17	SM		08/01/17

CITY OF OCEANSIDE

WATER SAMPLING STATION
FROM AN EXISTING WATER SERVICE

Steven E. Strapan 9/17/17
CITY ENGINEER Date

STANDARD DRAWING NO. **W-8**