



BILL OF MATERIALS:

1. SENSUS SERIES "W" COMPOUND METER WITH BUILT IN STRAINER & TEST OUTLET APPROXIMATELY 23" LONG.
2. VAULT FRAME AND COVER PER STANDARD DWG W-19 AND W-20.
3. VICTAULIC COUPLING.
4. RESILIENT WEDGE GATE VALVE, FLANGE X FLANGE WITH 2" OPERATING NUT.
5. SUPPORT METER WITH VALVE SUPPORTS PER STANDARD DWG W-18.

NOTES:

1. VAULT DEPTH NOT TO EXCEED 5'-0" FROM TOP OF VAULT TO FLOOR.
2. SERVICES 6" AND LARGER REQUIRE SPECIAL DESIGN.

Revision	By	Approved	Date
04/26/01	kal		
06/07/01	DW		
10/16/02	DW		
01/04/16	MU		
07/01/17	SM		08/01/17

CITY OF OCEANSIDE

**3" & 4" WATER METER
FOR IRRIGATION SERVICE**

Steven E. Strapan 9/17/17
CITY ENGINEER Date
STANDARD DRAWING NO. **W-11**