



* NOTE: ON TEMPORARY DEAD END STREETS THE BLOW-OFF SHALL BE PLACED BEHIND THE BARRICADE

** WHEN BLOW-OFF IS LOCATED IN PARKWAY

1. COVER SHALL BE PRINTED WITH "CITY OF OCEANSIDE RECYCLED WATER" PER SECTION 4 OF THE MANUAL.
2. EXPOSED PIPE SHALL BE PAINTED SAFETY PURPLE.

Revision	By	Approved	Date
07/26/99	kal		
08/06/04	AC		
09/29/15	IN		
07/01/17	SM		08/01/17

CITY OF OCEANSIDE

STANDARD 4" BLOW-OFF

Steven E. Strapac 9/17/17
 CITY ENGINEER Date
 STANDARD DRAWING NO. **RW-2**