


1. PRESSURE RELIEF VALVE CLAYTON 50G-01 WITH FACTORY FUSION BONDED EPOXY COATING INSIDE AND OUT W/STAINLESS STEEL TRIM.
 2. DUCTILE IRON FLANGED SPOOL, LENGTH AS REQUIRED.
 3. FLNG. GATE VALVE /RW (RESILIENT WEDGE VALVE) W/FACTORY FUSION BONDED EPOXY COATING INSIDE. WEDGE TO BE URETHANE RUBBER ENCAPSULATED DUCTILE IRON.
 4. DIP CL 150 OR PVC C900 CL 150, LENGTH 10'-15' TO DAYLIGHT OR DISCHARGE TO BE DESIGNED FOR A SPECIFIC SITE CONDITION. DIP TO BE WRAPPED PER SECTION 4.5.
 5. PRE-CAST VAULT PER STANDARD DWG RW-13.
 6. COVER PER STANDARD DWG RW-14
 7. VALVE SUPPORT PER STANDARD DWG NO. RW-12.
 8. VALVE BOX PER STANDARD DWG RW-15.
 9. FLAP GATE VALVE.
 10. APPROVED SEALANT AROUND PIPE OPENINGS.
 11. IF DISCHARGE PIPE IS RELEASED TO STORM DRAIN IT MUST BE AIR-GAPPED AND DIFFUSED.
 12. CHRISTY'S WARNING TAG MODEL ID-MAX-P2-RC007
- NOTE: ALL VALVES AND PIPING WITHIN THE VAULT SHALL BE PAINTED SAFETY PURPLE.

Revision	By	Approved	Date
11/06/00	kal		
06/11/01	DW		
10/18/02	DW		
09/30/15	IN		
07/01/17	SM		08/01/17

CITY OF OCEANSIDE

RELIEF VALVE

 9/17/17
 CITY ENGINEER Date
 STANDARD DRAWING NO. **RW-10**